



ADVANCED TEMPERATURE CONTROL

1416 GRAHAM'S LANE, BURLINGTON, ONTARIO L7S 1W3

TEL: (905) 637-3468

FAX: (905) 637-3363

Introduction

This document shows how to change the **M910166 (Control + Mounting Bracket)** to the **M910165 (Only Control)**.

Instructions:

1. Modify the received **M910135** back panel as shown below



2. Use an appropriate cross head screwdriver to remove the 4 screws indicated in image 1 of the figure below
3. Remove and discard the mounting bracket and the 4 screws from the product.
4. Install the modified **M910135** using the 4 new screws (2,5 x 6mm) as indicated in image 3 of the figure below.

